



Sanitary Sewer Overflow Annual Report

Division of Surface Water

Date: March 23, 2018
Facility name: City of Port Clinton Waste Water Treatment Plant
Ohio NPDES permit no.: 2PD00014*ND
Period covered by report: January 1, 2017 to December 31, 2017

Contact person

Name: David A. Bacak II
Title: Superintendent
Mailing address: 100 N. Jackson St., Port Clinton, OH 43452
Telephone: (419)734 - 3221
Email: pcwastewater@cros.net

Certification:

I certify under penalty of law that I have personally examined and am familiar with the information in this report and all attachments. Based on my inquiry of those persons immediately for obtaining the information contained in the report, I believe that the information is true, accurate, and complete.

Name David A. Bacak II **Title:** Superintendent
(typed): _____

Signature: _____ **Date:** _____

Enter narrative analysis of WIB patterns by location, frequency and cause.

The city had one Water in Basement Occurrence in the collection system during 2017.

Section #4

On November 3, 2017 due to debris in the line on Lincoln a resident had water in basement, sewer was jetted and flow restored to normal.