



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Craig W. Butler, Director

January 2, 2020

City of Port Clinton
1868 East Perry Street
Port Clinton, Ohio 43452

Re: City of Port Clinton
Rescission
Drinking Water Program
Ottawa County
PWS ID: OH6203211

Dear Public Water System:

It has been determined that Port Clinton City was not in violation of the maximum contaminant level (MCL) for Total Trihalomethanes (TTHM) during the 4th quarter 2019 monitoring period. Port Clinton City's locational running annual average (LRAA) for TTHM is 0.080 mg/L, which is at, but does not exceed, the MCL of 0.08 mg/L. Therefore, the TTHM MCL violation that was issued on December 10, 2019 is rescinded.

If you have any questions, please contact me at (614) 644-2752.

Sincerely,

A handwritten signature in cursive script that reads "Hayley Nininger".

Hayley Nininger (Hayley.nininger@epa.ohio.gov)

Compliance Assurance Section
Division of Drinking and Ground Waters